

GG-VL2-NH3 AMMONIA VENT LINE SENSOR



Installation and Operation Manual

Warning

**Use this product only in the manner described in this manual.
If the equipment is used in a manner not specified by Calibration Technologies, the protection provided by the equipment may be impaired.**

This equipment should be installed by qualified personnel.



Table of Contents

General description	4
Installation	4
Locating the sensor	4
Installation guidelines	5
Wiring	6
Operation	7
Start-up	7
Calibration	7
Maintenance.....	10
Troubleshooting.....	11
Specifications	11
Warranty.....	12

For technical support, contact:

Calibration Technologies

920 N Tradewinds Pkwy
Columbia, MO 65201

866-394-5861

sales@ctiengineering.com
www.ctiengineering.com

General Description

The GG-VL2-NH3 sensor is a +24 VDC, three-wire, 4/20 mA sensor for ammonia. It provides an industry standard linear 4/20 mA output signal compatible with most gas detection systems and PLCs.

The GG-VL2-NH3 provides real-time continuous monitoring of ammonia vapors in refrigeration system vent lines. Utilizing a long-life ammonia selective catalytic bead sensor, the GG-VL2-NH3 sensor can withstand occasional exposures to high concentrations of ammonia without shortening the life of the sensor.

The sensor element can be accessed from inside of the stainless steel enclosure, and is sealed from the vent line to prevent ammonia from entering the enclosure.

The transmitter circuit board is sealed in potting compound, protecting sensitive electronic components and copper tracing from corrosion.

Recommended alarm setpoints for ammonia system vent lines are typically 0.5% to 1.0% NH3 (12 to 20 mA).

Installation

Locating the sensor

Note: The ½" nipple of the supplied mounting kit should be welded to the relief header to allow airflow to the sensor.

Note: Removing the ½" plug from the mounting kit usually allows more fresh air to the sensor and prevents signal rise over time. Since fresh air promotes longer sensor life and overall long-term sensor performance, it is recommended that the sensor is installed outdoors.

Discharging to Atmosphere

The GG-VL2-NH3 sensor assembly should be installed outdoors three to five feet above the roofline, where the relief header discharges to the atmosphere (see Figure 1).

Discharging to Diffusion Tank

The GG-VL2-NH3 sensor assembly should be installed on the atmospheric vent on top of the water tank (see Figure 2). This type of installation will not catch the weeping relief valves, but will detect ammonia vapors from the water during a release event.

Caution: Installation of the sensor between SRV's and the diffusion tank will not allow fresh air in, so any introduction of ammonia gas will stay trapped in the header, resulting in a continuously high signal. A compressed air purge may be required for this. Contact Calibration Technologies for details.

Installation Guidelines:

- Always assume system could discharge at any moment. Stay clear of discharge path and have escape route planned.
- Make sure ammonia does not discharge onto sensor assembly or personnel working on sensor (i.e. mount sensor opposite side of discharge).
- Install sensor enclosure with conduit hole facing down.




Figure 1: Discharge to Atmosphere




Figure 2: Discharge to Diffusion Tank

Wiring

Electrical wiring must comply with all applicable codes.

Electrical Power: 24 VDC regulated, 80 mA.


Output: Linear 4/20 mA output. Monitoring equipment may have a maximum input impedance of 700 ohms.

Cable Recommendation: 20/3 shielded cable (General Cable C2525A or equivalent). Length of cable to sensor should be no greater than 1,500 feet.

Monitoring: Monitoring equipment must be configured to indicate a fault if the signal is below 1 mA. All signals over 20 mA must be considered high gas concentrations.

Wiring Guidelines:

- Use only the existing conduit hole for connections to the sensor.
- Always use three-conductor, insulated, stranded, shielded copper cable.
- Do not pull sensor wiring with AC power cables. This can cause electrical interference.
- If cable runs cannot be made without a splice, all splice connections should be soldered.
- Ground the shield at the main control panel. Connect the shield wire in the sensor terminal block labeled SHLD.
- Always disconnect power at the controller before performing any wiring at the sensor.



Terminal Block Plug (Field Wiring):

SHLD: To case (earth) ground of monitoring equipment

GND: To ground terminal of power supply

+24V: To +24V terminal of power supply

SIG: To signal input of monitoring equipment

Operation

Start-up

Before applying power, make a final check of all wiring for continuity, shorts, grounds, etc. It is usually best to disconnect external alarms until the initial start-up procedures are completed. Recommended sensor stabilization time is 5 minutes before making any adjustments.

Note: The GG-VL2-NH3 sensor must be zero-calibrated upon startup. Follow the Zero Calibration instructions on this page. Sensor can be response tested immediately after the initial zeroing.

Note: Do not response test with propane or MAPP gas, as these can shorten sensor life!

Response Test:

1. One person exposes each sensor to 1% or 2% NH₃ calibration gas.
2. The second person stays at the control panel to determine that each sensor, when exposed to the gas, is connected to the proper input and responds, causing appropriate alarm functions.

The GG-VL2-NH3 is designed with a unique safety signal latching feature. When the signal reaches 1% NH₃, the signal “latches” until the concentration drops down below approx 4,000 ppm NH₃. This prevents the possibility of a low reading when the gas

concentration exceeds the Upper Explosion Limit.

Calibration

The GG-VL2-NH3 sensor comes factory calibrated and should only require zero-calibration adjustment after installation. Calibration should be performed every six months. There are two pots on the preamp that are used for calibration (see Figure 3).

Note: Never measure sensor output in mA. Always use mVDC or VDC voltmeter settings.

Calibration Mode: Cal mode is required for calibrating the sensor. It clears the averaging, latching and deadband (factory set to 8 mA). Pressing the CAL switch enables cal mode and the green LED will flash. To exit out of cal mode, press the CAL switch or after 6 minutes it will automatically time-out back to normal mode.

Zero Calibration: After the unit is installed and has been powered up for a minimum of 1 hour, the unit can be zero calibrated by the following:

- Be sure the unit is in clean air. When in doubt, apply zero air gas.
- Press the CAL switch to enter cal mode. Do not adjust the zero pot if the green LED is not flashing.
- Adjust the zero pot until the sensor outputs 40 mVdc from Test [-] to Test [+] (see **Figure 3**).

Span Calibration: Do not adjust the span pot without certified calibration gas! If span adjustment is required, use the following procedure (see Figure 3):

- Unscrew calibration port cover and connect cal gas hose to hose barb fitting
- Press the CAL switch once to enter cal mode.
- Apply 1% NH₃ span gas at 0.5 to 0.8 L/min (span gas must be in air, not nitrogen or other carrier).
- Sensor should react to gas within 15 seconds.
- Once the output signal has peaked (or 2 minutes maximum) adjust the span pot until the correct output is achieved (200 mVdc).
- Shut-off gas, remove hose and replace cover.
- Press the CAL switch to exit cal mode.
- Calibration is now complete.

Note: Allow up to an hour for the signal to return back to 4 mA after exposure to high concentrations.

Note: If correct output during span adjustment is unachievable, replace the sensor element. See sensor replacement procedure on page 10 if a replacement sensor element is needed.

Note: Gas exposures well above the 0-1% NH₃ range of the sensor can shorten the life of the sensor element, and typically results in a "zero signal shift", where the signal is stuck at full-scale levels. Make sure no ammonia gas is present and simply re-zero the

sensor following the **Zero Calibration** procedure on the previous page.

4mA adjustment: Sometimes a fine adjustment of the 4mA signal may be desired to compensate for a slight positive or negative zero-signal reading on the control panel.

- Make sure the sensor is NOT in calibration mode.
- Adjust the 4mA pot until the control panel reads zero.




Figure 3: Transmitter and sensor assembly

Maintenance

The GG-VL2-NH3 was designed for long life and minimal maintenance. For proper operation it is essential that the calibration schedule be adhered to. Calibration Technologies recommends the following maintenance schedule:

Maintenance Guidelines:

- Sensor should be calibrated at 6 month intervals.
- Calibration should be performed with certified calibration gas. Calibration kits and replacement cylinders are available from Calibration Technologies.
- All tests and calibrations must be logged.
- Always disconnect power at the controller before performing any wiring at the sensor.

Sensor Life: This catalytic bead sensor exhibits long life and is very reliable. Typical sensor life is 5-7 years. As with all gas detectors, regular 6-month calibration intervals are essential to correct for sensor aging characteristics. A few conditions can cause the sensor to become faulty, including:

- a long period of time.
- exposure to liquid ammonia.
- poisoning due to silicon-based oils or lubricants, sulfur compounds or high concentrations of chlorine gas.

Sensor Replacement: (part #: GG-VL2-NH3-RS)

When the sensor becomes faulty, a replacement sensor element can be obtained from Calibration Technologies.

To replace the sensor, refer to **Figure 3** and the following procedure.

Caution: Always assume the system could discharge at any moment. Stay clear of discharge path and have an escape route planned.

1. Be prepared for fault/alarm conditions during this process.
2. Remove power from sensor. This can be done by simply unplugging the 4-position power plug from the transmitter.
3. Unplug sensor cable from transmitter.
4. Unscrew the sensor element assembly and discard old sensor.
5. A replacement O-ring is included in case existing O-ring is damaged or lost.
6. Screw in new replacement sensor assembly (do not overtighten).
7. Plug in sensor cable to transmitter.
8. Re-apply power to sensor
9. The sensor can be response-tested immediately after replacement but allow 12-hour warm-up time before performing zero/span calibration.

Troubleshooting

Sensor Fault: (0.5 mA signal output)

Indications: (any or all)

- Red LED on transmitter lit and voltage signal at testpoints is 5 mVdc (.5 mA output).
- PLC displays negative value (i.e. -2200 ppm).
- Controller indicates sensor fault or sensor failure

Possible Cause / Solution:

- Sensor exposed to liquid. Replace sensor element (see page 10 for more info).
- Loose connection. Check all sensor wires.

Constant or Intermittent high signal or alarms:

Possible Cause / Solution:

- Gas exposures well above the 0-1% NH₃ range of the sensor can shorten the life of the sensor element, and typically results in a "zero signal shift", where the signal is stuck at full-scale level. Make sure no ammonia gas is present and simply re-zero the sensor following the **Zero Calibration** procedure.
- Weeping relief valve. Check valve by drawing a sample from the header with an accurate portable ammonia detector. Be sure to sample 1' to 3' from inside the header to ensure a good reading.
- **Or** loosen union nut and remove sensor assembly from header. If signal returns to normal in fresh air, investigate relief valve(s) and replace if necessary.

Specifications

Input Power: +24 VDC, 80 mA

Detection Principle: Catalytic bead

Detection Method: Diffusion

Gas: Ammonia (NH₃)

Range: 0-1% (10,000 ppm) with 0.25% NH₃ deadband

Output Signal:

Linear 4/20 mA (max input impedance: 700 Ohms)

Response Time: T90 = less than 30 seconds

Accuracy: +/- 2% of full-scale

Zero Drift: Less than 0.1% of full-scale per month

Span Drift: Less than 2% of full-scale per month

Linearity: +/- 1% of full-scale

Repeatability: +/- 1% of full-scale

Wiring Connections:

3-conductor, shielded, stranded, 20 AWG cable (General Cable C2525A or equivalent) up to 1500 ft.

Terminal Block Plug (Field Wiring): 26-16 AWG, torque 4 lbs-in.

Enclosure: 18 gauge stainless steel housing. Captive screw in hinged lid. For non-classified areas.

Mounting Kit: Schedule 80 NPT pipe fittings

Temperature Range:

-40°F to +140°F (-40°C to +60°C)

Dimensions: 4.8" high x 4.72" wide x 3.35" deep

Weight: 4 lbs (includes mounting kit)

Certification:

ETL Listed: Conforms to UL 61010-1

Certified to CSA C22.2 No. 61010-1

Limited Warranty & Limitation of Liability

Calibration Technologies, Inc. (CTI) warrants this product to be free from defects in material and workmanship under normal use and service for a period of 2 years (including sensor element), beginning on the date of shipment to the buyer. This warranty extends only to the sale of new and unused products to the original buyer. CTI's warranty obligation is limited, at CTI's option, to refund of the purchase price, repair, or replacement of a defective product that is returned to a CTI authorized service center within the warranty period. In no event shall CTI's liability hereunder exceed the purchase price actually paid by the buyer for the Product.

This warranty does not include:

- a) gas sensors that have been wetted by liquid ammonia, oil or water;
- b) routine replacement of parts due to the normal wear and tear of the product arising from use;
- c) any product which in CTI's opinion, has been misused, altered, neglected or damaged by accident or abnormal conditions of operation, handling or use;
- d) any damage or defects attributable to repair of the product by any person other than an authorized dealer or contractor, or the installation of unapproved parts on the product

The obligations set forth in this warranty are conditional on:

- a) proper storage, installation, calibration, use, maintenance and compliance with the product manual instructions and any other applicable recommendations of CTI;
- b) the buyer promptly notifying CTI of any defect and, if required, promptly making the product available for correction. No goods shall be returned to CTI until receipt by the buyer of shipping instructions from CTI; and
- c) the right of CTI to require that the buyer provide proof of purchase such as the original invoice, bill of sale or packing slip to establish that the product is within the warranty period.

THE BUYER AGREES THAT THIS WARRANTY IS THE BUYER'S SOLE AND EXCLUSIVE REMEDY AND IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. CTI SHALL NOT BE LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, INCLUDING LOSS OF DATA, WHETHER ARISING FROM BREACH OF WARRANTY OR BASED ON CONTRACT, TORT OR RELIANCE OR ANY OTHER THEORY.



GG-VL2-DOC1-4
20180808

ctiengineering.com | 866-394-5861